

Response to Bidder Questions List #1

Replacement of Bridge No. 06955
Glen Street over Mattabesset River
Berlin, CT
State Project No. 0007-0266
Town Project No. 2026-12

BID OPENING 10:00 A.M. November 19, 2025

RESPONSE TO BIDDER QUESTIONS LIST #1

DATE OF RESPONSE: November 10, 2025

The following questions were received by the Engineer. Responses are provided directly below each question.

Bidder Question #1: There is no structure shown above the headwalls in Precast Headwall Detail Drawing No. S-11 regarding the protruding rebar in Typical Precast Headwall Detail. Can you please confirm whether we must provide the protruding rebar on the top of headwall as shown.

RESPONSE: The #5 @ 12" rebar protruding from the headwall shown in Typical Precast Headwall Detail in Dwg. S-11 is designed to tie into the concrete curb which is detailed in the Post Assembly – Section View shown in Dwg. No. S-14 and must be provided.

There is no change to the Bid Opening Date and Time.

There is no change to the Schedule of Prices.

There is no change in the number of calendar days

The foregoing is hereby made a part of the contract.