



NFPA110 (2002) Load Bank Test Report

Completed by:	STEVE ALLEN	Completed:	12/19/2022 17:12	Load Test Type:	Load Bank		
HPE Dispatch #:	83447	2nd Tech:	0				
Customer Number:	0013107	Location Number:	8	Location Name:	BERLIN GARAGE 130KW		
Site Address:	27 TOWN FARM RD	City:	BERLIN	State:	CT		
Generator Model #	99A-06077-S	Engine Model #	7.5L	Voltage:	277/480	Date:	19-Dec-22
Generator Serial #	2051176	Engine Serial #	NA	Phase:	3 PH	Start:	1:15:00 PM
Controller	E-Panel			Fuel:	Diesel	Stop:	3:15:00 PM

Duration	Voltage			Amperage			Load	Freq	Water	Oil	Battery	Fuel	Battery	Load	Comments
Hour	L1-L2	L2-L3	L3-L1	L1	L2	L3	KW	Hz	Temp	PSI	Chg Rate	Level/ Pressure	Voltage	P.F.	
0.00	481.0	479.0	480.0	40.0	41.0	40.0	35.0	60.0	155.0	54.0	0.8	NA	13.8	1.00	
0.25	481.0	480.0	480.0	40.0	42.0	40.0	35.0	60.0	162.0	48.0	0.8	NA	13.8	1.00	
0.50	480.0	480.0	480.0	75.0	74.0	74.0	65.0	60.0	174.0	44.0	0.8	NA	13.8	1.00	
0.75	480.0	480.0	478.0	75.0	74.0	74.0	65.0	60.0	174.0	44.0	0.8	NA	13.8	1.00	
1.00	479.0	480.0	480.0	110.0	109.0	107.0	95.0	60.0	174.0	44.0	0.8	NA	13.8	1.00	
1.25	480.0	480.0	479.0	108.0	109.0	108.0	95.0	60.0	174.0	44.0	0.8	NA	13.8	1.00	
1.50	480.0	480.0	479.0	108.0	109.0	108.0	95.0	60.0	174.0	44.0	0.8	NA	13.8	1.00	
1.75	480.0	480.0	479.0	108.0	109.0	108.0	95.0	60.0	174.0	44.0	0.8	NA	13.8	1.00	
2.00	480.0	480.0	479.0	108.0	109.0	108.0	95.0	60.0	174.0	44.0	0.8	NA	13.8	1.00	
														1.00	
														1.00	
														1.00	
														1.00	
														1.00	
														1.00	
														1.00	

Technician: _____
Signature: _____